




CONFORMITY CERTIFICATE OF EXPLOSION-PROOF

Certificate No.: CE21.1561

Name of Product: Explosion-proof LED lightings
Type of Product: BZD133-12-3
Marking: **Ex nA e mc II C T6 Gc; Ex tD A21 IP66 T80 °C**
Technical Documents: Q/XLM 219-2021
Drawing No.: 2XLM 511 1111
Note (s):

For notes of this certificate see annex.



By verifying the drawings and technical documents and checking samples, the product complies with the following standards:

GB 3836.1-2010 GB 3836.3-2010 GB 3836.8-2014 GB 3836.9-2014
GB 12476.1-2013 GB 12476.5-2013

Issued to: SUNLEEM TECHNOLOGY INCORPORATED COMPANY

Date of Expire: 2026-05-19

Date of Issue: 2021-05-19

Center seal



Director

Liu Hongguang

National Ex-Product Quality Supervision and Inspection Center(TianJin)
(Supervision & Test Center of Ex- products of China Petroleum & Chemical Industry)



ANNEX OF CONFORMITY CERTIFICATE OF EXPLOSION-PROOF

Certificate No.: CE21.1561

1. Rated voltage: AC100V~240V.
2. Source of light type and power: LED light, 30W, 50W.
3. IP code: IP66.
4. means lamp power; means mounting type: x-Ceiling, g-Pendant, b-Basket, h-Fence, f-Flange, d-Hanging chain, w- Bend; J-with emergency function (no matching not noted).
5. Installing direction: in the range from horizontal to vertically downward.
6. Ambient temperature: $-40^{\circ}\text{C} \leq T_a \leq +40^{\circ}\text{C}$.

None



National Ex-Product Quality Supervision and Inspection Center(TianJin)
(Supervision & Test Center of Ex- products of China Petroleum & Chemical Industry)

Note: This certificate is only valid for the documents approved and for the products that are in accord with samples tested and verified.
Center Add: No.85 No.3 Road DingZiGu Tianjin China Post code: 300131 Tel/ Fax: 022-26651066/26689116
E-mail:pcec@pcec.com.cn <http://www.pcec.com.cn>