



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

No.: 2019312311000089

Applicant Sunleem Technology Incorporated Company
Address #15 Xihenggang Street, Yangchenghu Town, Xiangcheng District, Suzhou, Jiangsu 215138 , China

Manufacturer Sunleem Technology Incorporated Company
Address #15 Xihenggang Street, Yangchenghu Town, Xiangcheng District, Suzhou, Jiangsu 215138 , China

Production Factory Sunleem Technology Incorporated Company
Production Address #15 Xihenggang Street, Yangchenghu Town, Xiangcheng District, Suzhou, Jiangsu 215138 , China

Product Explosion-proof split wall-mounted air conditioner
Model/Type BKFR
Ex marking Ex d e ib mb IIC T4 Gb
Reference Standards GB3836.1-2010, GB3836.2-2010, GB3836.3-2010
GB3836.4-2010, GB3836.9-2014

Certification mode Type Test + Initial Factory Inspection + Post-Certification Surveillance

The product(s) is verified and certified according to CNCA-C23-01: 2019 *China Compulsory Certification Implementation Rule on Explosion Protected Electrical Product* and CNEC-C2301-2019 *Guideline of China Compulsory Certification Implementation Rule on Explosion Protected Electrical Product*.

See Annex for the detailed product information (1 page)

Issued on: 2019-11-22

Valid to: 2024-11-21

The validity of this certificate is maintained through the regular supervision of the issuing authority during the validity period.

Where any discrepancy arises between the English translation and the original Chinese version, the Chinese version shall prevail.

Director:



Nanyang Explosion Protected Electrical Apparatus Research Institute Co.,Ltd.



<http://www.ccc-cnex.com>
ccc.china-ex.com

Add: No. 20, North Zhongjing Road, Nanyang, Henan, P. R. China P.C.: 473008
Tel: 0377-63239734 Email: ccc@cn-ex.com

CN 0000761



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION (Annex)

No.: 2019312311000089

Page 1 of 1

Product information:

1. This certificate covers the following models:

- BKFR-72/220 refrigerating capacity: 7200W, heat capacity: 8100W

BKFR-23/220 refrigerating capacity: 2300W, heat capacity: 2500W

BKFR-35/220 refrigerating capacity: 3500W, heat capacity: 4200W

BKFR-50/220 refrigerating capacity: 5000W, heat capacity: 5800W

Rated voltage: 220V AC

Ex marking: Ex d e ib mb IIC T4 Gb

- Producers should organize production in accordance with the technical documents approved by the certification body.

2. Specific conditions of safety use:

See instruction.

3. Certificate related report(s):

- Type test report: CQST1911X500

4. Certificate change information: None

Issued on: 2019-11-22

Director:



Nanyang Explosion Protected Electrical
Apparatus Research Institute Co., Ltd.

